



Wels, March 23rd 2017

DC-INJECTION REQUIREMENTS OF SINGAPORE

Fronius International GmbH

hereby confirms that the inverters

/ **Fronius Primo 3.0-1 – 8.2-1**

/ **Fronius Symo 10.0-3-M – 20.0-3-M**

do not exceed the DC-injection limit of 20 mA according to the test reports listed in the following Table.

Inverter	Test report number
Fronius Primo:	
Fronius Primo 3.0-1	TR22914
Fronius Primo 3.5-1	TR22915
Fronius Primo 3.6-1	TR22916
Fronius Primo 4.0-1	TR23020
Fronius Primo 4.6-1	TR23021
Fronius Primo 5.0-1	TR23022
Fronius Primo 6.0-1	TR23023
Fronius Primo 8.2-1	TR23024
Fronius Symo:	
Fronius Symo 10.0-3-M	TR20120
Fronius Symo 12.5-3-M	TR20121
Fronius Symo 15.0-3-M	TR20122
Fronius Symo 17.5-3-M	TR20123
Fronius Symo 20.0-3-M	TR20124

Fronius International GmbH

Solar Energy Division

Froniusplatz 1

A-4600 Wels

DI Thomas Mühlberger
Head of Solution Management